

To: Kelly, Jack (R3 Phila.)[Kelly.Jack@epa.gov]
Cc: ValentineDavis, Victor[Victor.ValentineDavis@hq.dhs.gov]; Chacko, Betsie[betsie.chacko@HQ.DHS.GOV]
From: Chacko, Betsie
Sent: Fri 2/14/2014 6:55:41 PM
Subject: RE: HOTSITE REPORT: Update - Freedom Industries, Charleston, WV

Hi Jack,

Thank you so much for forwarding the HOTSITE reports – they have been very helpful! The NOC has closed out this incident and therefore we will no longer need these reports.

Thanks to your efforts, we were able to provide all the requested information to our leadership. We very much appreciate your help!!! Please don't hesitate to contact us if we can support you in the future. Thank you for everything!

Thank you,

Betsie Chacko

Deputy Section Chief

CBRNE Section | Interagency Modeling & Atmospheric Assessment Center

Current Operations | Office of Operations Coordination & Planning

Department of Homeland Security

(: 202-282-8743 | *: betsie.chacko@hq.dhs.gov)

From: Kelly, Jack (R3 Phila.) [mailto:Kelly.Jack@epa.gov]
Sent: Friday, February 14, 2014 1:14 PM
To: Adam Hamrick (hamrick.adam@dol.gov); Gilbert, John; Smith, Art; Kathleen Patnode (kathleen_patnode@fws.gov); Chacko, Betsie; Jerry Schulte
Subject: FW: HOTSITE REPORT: Update - Freedom Industries, Charleston, WV

Jack Kelly

On Scene Coordinator

EPA Region III, Philadelphia

215-514-6792 (cell)

215-814-3112 (office)

From: Burns, Francis

Sent: Friday, February 14, 2014 1:09 PM

To: R3 HOTSITES

Subject: HOTSITE REPORT: Update - Freedom Industries, Charleston, WV

Vicky Binetti of Region 3's Water Program reported that the residential sampling study in the service area of WV American Water Company's Elk River plant (Kanawha district) is apparently underway. The home drinking water study is one of three elements of the West Virginia Testing Assessment Project (WV TAP) study, which also includes convening expert panels to review the health screening level for MCHM and the odor threshold for MCHM. The study description indicates that an initial assessment (underway) will be completed in approximately three weeks, and will be followed by a larger scale effort. Information on the study and the research team is available at <http://www.dhsem.wv.gov/Pages/WV-American-Water-Emergency.aspx>, under the heading WV Testing Assessment Project.

EPA provided information to the WV Bureau for Public Health and Region 3 ATSDR-CDC to address questions forwarded by Commissioner Dr. Letitia Tierney regarding potential MCHM degradation products, fate, transport and toxicity. A team of EPA engineers, scientists and researchers convened by Region 3 prepared the response to these specific questions. The EPA team is continuing to look into the potential formation of degradation and disinfection products in the drinking water system.

OSC Dennis Matlock reported that WVDEP and the Attorney General Office, along with the Chemical Safety Board, have indicated that they would allow Freedom Industries to begin demolition plans to remove tanks 393 and 394, which are located at the far northern end of the facility. The facility is scheduled to meet with the Charleston Sanitation Board on Wednesday, February 19, 2014, to discuss disposal of the stored water via POTW.

A contractor of the plaintiff's lawyer attempted to run a camera through the culvert pipe that runs beneath the containment pad. Due to mud, leaves, and debris, the camera was unable to move through the pipe.

The facility attempted to excavate an interceptor trench in the eastern area of the containment. However,

an unidentified pipe was discovered, along with petroleum odor. This operation was suspended. Two roll-offs containing the MCHM-contaminated liners and soil were transported off-site for disposal.